

Daily Generation Report of 04 May- 2024

Reporting Date 05 May - 2024

| SL NO | Name Of Power Station | CAPACITY (MW) | GENERATION OF THE DAY (MU) | | | | | Cumulative Gen. of the month till date (MU) | Cumulative Gen. In FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) | | | | | | | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks |
|--------------|-----------------------|----------------|----------------------------|--------|--------|--------|---------------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|--------------|-----------------------------------|----------------|---------------------|------------------------------------|--|
| | | | Unit-1 | Unit-2 | Unit-3 | Unit-4 | Total | | | B/D of Equipment | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons | Total | | | | | |
| 1 | CHIBRO | 4x60=240 | 0.344 | PO | 0.672 | 0.171 | 1.188 | 4.825 | 42.613 | | | | | | | 0.000 | 150 | 63 | 63 | 0.480 | Unit 2 is in PO since 30.04.2024 |
| 2 | KHODRI | 4x 30 = 120 | 0.084 | 0.339 | 0.003 | 0.173 | 0.599 | 2.441 | 22.341 | | | | | | | 0.000 | 74 | 62 | 62 | 0.236 | |
| 3 | DHAKRANI | 3x11.25=33.75 | RMU | 0.067 | 0.158 | | 0.225 | 0.906 | 8.057 | | | | | | | 0.000 | 18 | 54 | 54 | 0.050 | Unit 1 is in RMU since 16.02.2024 |
| 4 | DHALIPUR | 3x17 = 51 | 0.085 | 0.055 | 0.228 | | 0.367 | 1.515 | 13.319 | | | | | | | 0.000 | 33 | 64 | 64 | 0.102 | |
| 5 | KULHAL | 3x 10= 30 | 0.068 | PO | 0.177 | | 0.245 | 1.037 | 9.222 | | | | | | | 0.000 | 20 | 67 | 67 | 0.050 | Unit 2 is in AM since 06.04.2024 |
| 6 | TILOTH (MB-I) | 3x30=90 | 0.700 | 0.701 | PO | | 1.401 | 4.581 | 32.517 | | | | | | | 0.000 | 68 | 76 | 76 | 0.715 | Unit 3 is in AM since 22.03.2024 |
| 7 | DHARASU (MB-II) | 4x 76 = 304 | 1.007 | PO | 0.249 | 1.289 | 2.545 | 8.522 | 68.408 | | | | | | | 0.000 | 229 | 76 | 76 | 0.688 | Unit 2 is in AM since 17.03.2024 |
| 8 | CHILLA | 4x 36 = 144 | 0.565 | 0.585 | PO | 0.333 | 1.483 | 5.801 | 62.875 | | | | | | | 0.000 | 68 | 48 | 48 | 0.221 | Unit 3 is in CM since 11.02.2024 |
| 9 | RAMGANGA | 3x 66 = 198 | 0.768 | 0.870 | 0.846 | | 2.484 | 9.961 | 33.272 | | | | | | | 0.000 | 104 | 53 | 53 | 2.484 | |
| 10 | KHATIMA | 3x 13.8 =41.40 | 0.087 | 0.147 | 0.101 | | 0.335 | 1.138 | 13.365 | | | | | | | 0.000 | 21 | 51 | 41 | 0.094 | |
| 11 | PATHRI | 3x6.8=20.4 | 0.117 | 0.119 | 0.115 | | 0.351 | 1.391 | 11.466 | | | | | | | 0.000 | 18.0 | | 0 | 0.060 | |
| 12 | MOHD. PUR | 3x 3.1 =9.30 | FO | 0.063 | 0.061 | | 0.124 | 0.503 | 4.517 | 0.012 | | | | | | 0.012 | 5.3 | | 0 | 0.031 | Unit 1 is in FO due to Thrust bearing temp high since 23.04.2024 |
| 13 | GALOGI | 3X1+0.5 = 3.5 | RO | RO | RO | 0.015 | 0.015 | 0.061 | 0.508 | | | | | | | 0.000 | 0.6 | | 0 | 0.002 | |
| 14 | DUNAO | 2x.75=1.5 | RO | RO | | | 0.000 | 0.000 | 0.091 | | | | | | | 0.000 | 0.0 | | 0 | 0.000 | |
| 15 | PILANG GAD | 2x1.125=2.25 | 0.012 | 0.014 | | | 0.026 | 0.149 | 1.130 | | | | | | | 0.000 | 1.8 | | 0 | 0.009 | |
| 16 | URGAM | 2x1.5=3.00 | RO | 0.005 | | | 0.005 | 0.063 | 0.656 | | | | | | | 0.000 | 1.3 | | 0 | 0.007 | |
| 17 | KALIGANGA-I | 2x2=4.00 | 0.032 | RO | | | 0.032 | 0.115 | 0.839 | | | | | | | 0.000 | 1.7 | | 0 | 0.005 | |
| 18 | VYASI | 2x60=120 | 0.139 | 0.134 | | | 0.273 | 1.087 | 8.646 | | | | | | | 0.000 | 90 | | | 0.273 | |
| 19 | KALIGANGA-II | 2x2.25=4.5 | 0.032 | RO | | | 0.032 | 0.145 | 1.330 | | | | | | | 0.000 | 2.1 | | | 0.007 | |
| 20 | SURINGAD-II | 2x2.5=5 | RO | RO | | | 0.000 | 0.000 | 0.000 | | | | | | | 0.000 | 0.0 | | | 0.000 | |
| TOTAL | | | 1425.60 | | | | 11.728 | 44.241 | 335.170 | 0.012 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.012 | 905.30 | | | 5.513 | |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:- Chairman /Secretary(Energy) Govt of Uttarakhand.
MD UJVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)