

Daily Generation Report of 06 April- 2024

Reporting Date 07 April - 2024

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. In FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	0.692	FO	0.339	PO	1.031	7.596	7.596							0.000	105	44	44	0.342	Unit 4 is in CM since 28.12.2023 Unit 2 is in FO due to leakage in turbine since 26.03.2024
2	KHODRI	4x 30 = 120	0.371	RO	0.145	0.029	0.545	4.055	4.055							0.000	54	45	45	0.162	
3	DHAKRANI	3x11.25=33.75	RMU	0.097	0.119		0.216	1.490	1.490							0.000	19	55	55	0.055	Unit 1 is in RMU since 16.02.2024
4	DHALIPUR	3x17 = 51	PO	0.164	0.205		0.368	2.466	2.466							0.000	33	64	64	0.102	Unit 1 is in AM since 26.03.2024,
5	KULHAL	3x 10= 30	0.158	PO	0.097		0.255	1.679	1.679							0.000	20	67	67	0.050	Unit 2 is in AM since 06.04.2024
6	TILOTH (MB-I)	3x30=90	0.128	0.586	PO		0.715	3.724	3.724							0.000	68	76	68	0.257	Unit 3 is in AM since 22.03.2024
7	DHARASU (MB-II)	4x 76 = 304	0.241	PO	0.334	1.236	1.811	10.409	10.409							0.000	229	76	65	0.688	Unit 2 is in AM since 17.03.2024
8	CHILLA	4x 36 = 144	0.697	0.706	PO	0.536	1.939	12.111	12.111							0.000	95	67	67	0.286	Unit 3 is in CM since 11.02.2024
9	RAMGANGA	3x 66 = 198	RO	RO	RO		0.000	0.511	0.511							0.000	0	0	3	0.000	
10	KHATIMA	3x 13.8 =41.40	0.096	RO	0.283		0.379	2.331	2.331							0.000	29	71	69	0.103	
11	PATHRI	3x6.8=20.4	0.143	0.147	RO		0.289	1.393	1.393							0.000	13.6			0.061	
12	MOHD. PUR	3x 3.1 =9.30	0.063	RO	0.068		0.131	0.637	0.637							0.000	5.8			0.031	
13	GALOGI	3X1+0.5 = 3.5	PO	RO	RO	0.016	0.016	0.098	0.098							0.000	0.7			0.002	Unit 1 is in AM since 12.03.2024
14	DUNAO	2x.75=1.5	0.005	RO			0.005	0.037	0.037							0.000	0.5			0.014	
15	PILANG GAD	2x1.125=2.25	0.014	0.016			0.030	0.209	0.209							0.000	1.6			0.005	
16	URGAM	2x1.5=3.00	RO	RO			0.000	0.000	0.000							0.000	0.0			0.000	
17	KALIGANGA-I	2x2=4.00	0.021	RO			0.021	0.127	0.127							0.000	1.0			0.005	
18	VYASI	2x60=120	PO	0.246			0.246	1.585	1.585							0.000	60			0.246	Unit 1 is in AM since 12.03.2024
19	KALIGANGA-II	2x2.25=4.5	0.044	RO			0.044	0.252	0.252							0.000	2.0			0.011	
20	SURINGAD-II	2x2.5=5	RO	RO			0.000	0.000	0.000							0.000	0.0			0.000	
TOTAL			1425.60				8.041	50.710	50.710	0.000	0.000	0.000	0.000	0.000	0.000	0.000	736.18			2.420	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:- Chairman /Secretary(Energy) Govt of Uttrakhand.
MD UJVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)