

Daily Generation Report of 20 May- 2024

Reporting Date 21 May - 2024

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. In FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	1.135	0.267	1.157	0.055	2.615	36.947	74.735							0.000	155	65	64	0.774	
2	KHODRI	4x 30 = 120	0.590	RO	0.156	0.583	1.328	18.907	38.807							0.000	76	64	63	0.247	
3	DHAKRANI	3x11.25=33.75	RMU	0.216	0.218		0.434	2.891	10.042							0.000	19	55	30	0.135	Unit 1 is in RMU since 16.02.2024
4	DHALIPUR	3x17 = 51	0.370	0.250	0.132		0.751	4.880	16.684							0.000	34	67	35	0.215	
5	KULHAL	3x 10= 30	0.211	0.023	0.226		0.459	3.143	11.328							0.000	20	67	37	0.150	
6	TILOTH (MB-I)	3x30=90	0.814	0.815	PO		1.630	30.451	58.386					0.602		0.602	68	76	76	1.630	Unit 3 is in AM since 22.03.2024
7	DHARASU (MB-II)	4x 76 = 304	1.731	1.726	1.689	1.698	6.844	85.880	145.766							0.000	289	96	86	0.870	
8	CHILLA	4x 36 = 144	0.743	0.774	PO	0.659	2.176	36.355	93.429							0.000	95	67	59	0.564	Unit 3 is in CM since 11.02.2024
9	RAMGANGA	3x 66 = 198	0.764	0.963	0.375		2.102	48.088	71.399							0.000	92	47	51	2.102	
10	KHATIMA	3x 13.8 =41.40	0.237	0.241	0.244		0.722	9.784	22.011							0.000	32	78	59	0.177	
11	PATHRI	3x6.8=20.4	0.141	0.146	0.162		0.449	8.122	18.197							0.000	19.2			0.065	
12	MOHD. PUR	3x 3.1 =9.30	0.046	0.046	0.046		0.138	2.983	6.997							0.000	6.1			0.034	
13	GALOGI	3X1+0.5 = 3.5	RO	PO	RO	0.010	0.010	0.278	0.725			0.005				0.005	0.6			0.002	Unit 2 is in CM since 10.05.2024 Due to Grid disturbance
14	DUNAO	2x.75=1.5	RO	0.001			0.001	0.046	0.14							0.000	0.6			0.000	
15	PILANG GAD	2x1.125=2.25	0.015	0.014			0.029	0.723	1.704							0.000	1.5			0.009	
16	URGAM	2x1.5=3.00	0.010	0.009			0.018	0.826	1.418							0.000	2.0			0.006	
17	KALIGANGA-I	2x2=4.00	0.040	RO			0.040	0.711	1.435							0.000	2.0			0.009	
18	VYASI	2x60=120	0.139	0.143			0.281	5.968	13.527							0.000	90			0.281	
19	KALIGANGA-II	2x2.25=4.5	0.040	RO			0.040	0.634	1.818							0.000	2.3			0.011	
20	SURINGAD-II	2x2.5=5	0.010	RO			0.010	0.022	0.022							0.000	1.1			0.001	
TOTAL			1425.60				20.078	297.639	588.568	0.000	0.005	0.000	0.000	0.602	0.000	0.607	1004.90			7.282	

Distributed to:- Chairman /Secretary(Energy) Govt of Uttarakhand.
MD UJVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)